

A. General Information

A.2 Key Contact Information

Operator:

John Poppe

(Name of Operator)

9278 Morningside Drive N.W.

(Mailing Address)

Silverdale

(City)

WA

(State)

98383

(Zip Code)

N/A

(Daytime Phone Number)

N/A

(Fax Number)

360 340-8372

(Cell Phone Number)

Poppe.john@gmail.com

(Email)

Owner:

The Port of Bremerton

(Name of Owner)

8850 SW State Highway 3

(Mailing Address)

Bremerton

(City)

WA

(State)

98312

(Zip Code)

360 674-2381

(Daytime Phone Number)

360 674-2807

(Fax Number)

360 731-0523

(Cell Phone Number)

freds@portofbremerton.org

(Email)

Design Engineer:

Bovey Engineering

(Name of Design Engineer)

1101 North Argonne Road, Suite 201

(Mailing Address)

Spokane

(City)

WA

(State)

(Zip Code)

(Daytime Phone Number)

(Fax Number)

(Cell Phone Number)

No Longer in business

(Email)

Installer:

N/A

(Name of Installer)

(Mailing Address)

(City)

(State)

(Zip Code)

(Daytime Phone Number)

(Fax Number)

(Cell Phone Number)

(Email)

Electrician:

Port of Bremerton

(Name of Electrician)

8850 SW State Highway 3

(Mailing Address)

Bremerton

(City)

WA

(State)

98312

(Zip Code)

360 674-2381

(Daytime Phone Number)

360 674-2807

(Fax Number)

(Cell Phone Number)

lamarrw@portofbremerton.org

(Email)

Solids Disposal Pumper:

Kitsap Septic

(Name of Pumper)

5201 E. Hillcrest Dr.

(Mailing Address)

Port Orchard

(City)

WA

(State)

98366

(Zip Code)

360 871-5258

(Daytime Phone Number)

N/A

(Fax Number)

N/A

(Cell Phone Number)

N/A

(Email)

Management Entity:

The Port of Bremerton

(Name of Management Entity)

8850 SW State Highway 3

(Mailing Address)

Bremerton

(City)

WA

(State)

98312

(Zip Code)

360 674-2381

(Daytime Phone Number)

360 674-2807

(Fax Number)

360 536-7261

(Cell Phone Number)

Lamarrw@portofbremerton.org

(Email)

Primary Contact Person for Management Entity:

Lamarr Wright

(Name of Primary Contact Person for Management Entity)

8850 SW State Highway 3

(Mailing Address)

Bremerton

(City)

WA

(State)

98312

(Zip Code)

360 674-2381 Ext 28

(Daytime Phone Number)

360 674-2807

(Fax Number)

360 536-7261

(Cell Phone Number)

Lamarrw@portofbremerton.org

(Email)

Third Party Guarantor (if any):

N/A

(Name of Third Party Guarantor)

(Mailing Address)

(City)

(State)

(Zip Code)

(Daytime Phone Number)

(Fax Number)

(Cell Phone Number)

(Email)

Washington State Department of Health (DOH):

Katherine Rottell

(Name of Approving Engineer or DOH Engineer you now work with)

P.O. Box 47824

(Mailing Address)

Olympia

(City)

WA

(State)

98504

(Zip Code)

360 236-3318;360-236-3330

(DOH Engineer Number; Mainline)

360 236-2257

(Fax Number)

N/A

(Cell Phone Number)

Katherine.rottell@doh.wa.gov; wastewatmgmt@doh.wa.gov

(DOH Engineer Email; WWMS Generic Email)

A. General Information

A.3 Owner Responsibilities

CALL BEFORE YOU DIG: 1-800-562-6150

Owners of LOSS (defined by L&I as facility operators) must subscribe to a one-number locator service per RCW 19.122 (see Section G of this manual). ‘Call Before You Dig’ requirements apply when repairing or replacing buried LOSS components. You will also be notified to identify where your lines and tanks are buried if underground work is going to be done in your area.

- a. The owner shall obtain an operating permit from the department and shall renew it annually as long as the LOSS is in service.
- b. The owner shall employ a qualified operator(s) at all times.
- c. The owner shall submit an annual operating report prepared and signed by the qualified operator.
- d. The owner shall employ an approved management entity at all times.
- e. The owner shall ensure that reliable and representative monitoring following operating permit requirements is conducted and that results are provided to the department.
- f. The owner shall notify the department within five calendar days when the LOSS is not in compliance with an operating permit monitoring limit or condition.
- g. The owner shall address and correct all failures immediately and shall report the condition to the department within one business day of discovery.
- h. The owner shall ensure that financial resources are sufficient for O&M of the LOSS.
- i. The owner, along with the operator is responsible for ensuring that certain substances do not enter the LOSS collection system. These include:
 - Strong bases, acids, chlorinated solvents, or other toxic or hazardous substances
 - Fire or explosion hazards
 - Solid or viscous wastes that could plug sewer lines
 - Drainage from surface runoff, footing drains, roof drains, subsurface storm water infiltration systems, swimming pools, and other non-sewage drains
 - Industrial wastewater
- j. The owner shall respond to customer concerns and service complaints in a timely manner.