

June 15, 1987

Teral Inc. P.O. Box 238 Cheshire, OR 97419

RE: Specifications for Bremerton W.W.T.F.

Dear Terri;

After reveiwing the specifications for the above mentioned project which are contained in specification section 2590-3 2.08, sewage lagoon liner, we will certify the liners to have the following minimum physical properties and do conform to the appropriate ASTM tests.

Service life
Elongation to break
Tensile Strength
Thickness Variation
Water Absorption (7 days)
Seam strength

20 years
250 percent
1000 psi
10 percent maximum
5 percent maximum
same as liner

Attached you will find material sample and factory seam sample, as requested.

Sincerely Yours:

Paul Kwake;

American Plastics